

Water Quality Report for Irrigation

EFMA Primary Network

Lab results			
Responsible Laboratory: Labelec		(Bulletin n.º 797/19)	Water Quality for Irrigation (annex XVI, DL n.º 236/98)
Parameters	Units	Results	Conformity
Alkalinity	mg/L CaCO ₃	127	
Ammonium	mg/L NH ₄	0,05	
Nitrogen Kjeldahl	mg/L N	0,5	
Total Nitrogen	mg/L N	0,5	
Bicarbonates	mg/L CO ₃ H-	148	(a)
Boron	mg/L B	0,0267	●
Calcium	mg/L Ca	44	
Chloride	mg/L Cl	56	●
Total Hardness	mg/L CaCO ₃	192	
Total Iron	mg/L Fe	0,04	●
Phosphates	mg/L P ₂ O ₅	<LQ	0,007
Total Phosphorus	mg/L P	0,012	
Magnesium	mg/L Mg	20	
Manganese	mg/L Mn	0,0068	●
Nitrates	mg/L NO ₃	<LQ	0,3
Nitrites	mg/L NO ₂	<LD	0,003
Potassium	mg/L K	6,52	
Ratio of Sodium Absorption (SAR)		1,1	●
Ratio of Sodium Absorption adjusted (SARaj)		1,2	
Sodium	mg/L Na	36	
Total Dissolved Solids (TDS)	mg/L	298	●
Total Suspended Solids (TSS)	mg/L	<LQ	3
Sulphates	mg/L CO ₄	48	●
Total Coliforms	NMP/100 mL	199	
Fecal Coliforms	NMP/100 mL	0	●

Note: The tests to determine the parameters are included in the range of laboratory accreditation.

Field Results (Determined with a multiparameter probe)			Water Quality for Irrigation (annex XVI, DL n.º 236/98)
Parameters	Units	Results	Conformity
Temperature	°C	25,42321	
pH	Escala Sorensen	8,7	●
Conductivity	µS/cm	551	●


- Lower than the VMR (Maximum Value Recommended)
- Higher than VMR and below the VMA (Maximum Permitted Value)
- Higher than VMR. For this parameter is not defined one VMA.
- Higher than the VMA

(a) The maximum value recommended in the Integrated Production Standards, for most crops, is 90 mg / L.
(b) The VMA defined in Annex XVI of the Decree-Law No. 236/98 refers to the dissolved iron (5 mg / L Fe).

Sampling Data: 25-06-2019
Sampling Place: Alqueva-Captação (near the capture of Álamos)

Benefited areas:

The capture of Álamos adds water to the entire Alqueva subsystem, which includes the Álamos, Loureiro, Reservatório R4, Monte Novo, Alvito, Odivelas, Pisão, Cinco Reis, Penedrão, Roxo and Vale do Gaió reservoirs.



Comments:

The pH result exceeds the Recommended Maximum Value range for water quality for irrigation (VMR: [6.5-8.4]). This may be due to an increase in the biological activity of algae. High pH values can affect the plant's ability to absorb nutrients and promote the precipitation of iron, calcium, magnesium and phosphate ions, which may promote the clogging of drip irrigation systems. The bicarbonates results exceed the maximum recommended in the Integrated Production Standards. High concentrations of bicarbonates can affect crop yields, making it difficult to absorb some mineral nutrients. In the document "Water Quality - Complementary Information", EDIA recommends some general measures to reduce the concentration of salts in the water bodies.

The results of the other parameters are within the ranges of normal values for this type of water bodies.